




Mastercool[®]
"World Class Quality"

Superheat Determination Set 91499



1. Connect core remover to service tool.
 2. Connect service tool to system.
 3. Remove core valve & pull core removal tool back.
 4. Close service valve.
 5. Remove valve core remover and install thermometer.
 6. Open service valve and insert thermometer.
 7. Connect manifold gauge to service tool. Hose must have Depressor!
- Note system pressure T2 and temperature T1.